

**ADDENDUM NO. 2**

**October 7, 2008**

**REQUEST FOR PROPOSAL**

**CONTRACT FM 08-01**

**FURNISH TWO (2) PORTABLE 4-INCH AUTOMATIC SELF PRIMING PUMP  
SYSTEMS**

The following is an addendum to the Request for Proposal for the above project:

1. Question: reference Section 2.02.01.  
Is the 200 LF of discharge hose and 20 LF of suction hose total for both pumps or for one pump?

Answer: The Pump System shall have 200 LF of discharge hose for each pump and 20 LF of suction hose for each pump.

Prepared by: New Jersey Meadowlands Commission

---

Paula Speers  
Grants & Contracts Administrator